

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: April 2021


State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
04/01/2021	7.89	23.5	Yes
04/02/2021	7.83	22.0	Yes
04/03/2021	7.81	22.5	Yes
04/04/2021	7.87	22.5	Yes
04/05/2021	8.08	23.0	Yes
04/06/2021	7.91	21.5	Yes
04/07/2021	7.79	22.0	Yes
04/08/2021	7.90	22.5	Yes
04/09/2021	7.84	22.3	Yes
04/10/2021	7.85	22.5	Yes
04/11/2021	7.84	22.5	Yes
04/12/2021	7.85	21.0	Yes
04/13/2021	7.88	22.5	Yes
04/14/2021	7.82	24.0	Yes
04/15/2021	7.86	23.5	Yes
04/16/2021	7.77	22.5	Yes
04/17/2021	7.80	24.0	Yes
04/18/2021	7.85	22.0	Yes
04/19/2021	7.93	23.0	Yes
04/20/2021	7.91	22.5	Yes
04/21/2021	7.92	23.0	Yes
04/22/2021	7.85	22.5	Yes
04/23/2021	7.90	22.5	Yes
04/24/2021	7.90	23.5	Yes
04/25/2021	7.95	22.5	Yes
04/26/2021	7.82	22.0	Yes
04/27/2021	7.90	22.5	Yes
04/28/2021	7.92	22.0	Yes
04/29/2021	7.87	22.5	Yes
04/30/2021	7.81	22.0	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y / N

Supervisor's Signature



Print Name

Bret Bienenrth

Certification #:

08749

Phone (503) 635-0394

06-May-21