

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: May 2021

**State Minimum = 7.2 pH**

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
05/01/2021	7.81	22.0	Yes
05/02/2021	7.83	21.0	Yes
05/03/2021	7.92	21.0	Yes
05/04/2021	7.87	20.5	Yes
05/05/2021	7.85	21.0	Yes
05/06/2021	7.87	22.0	Yes
05/07/2021	7.88	21.5	Yes
05/08/2021	7.91	22.0	Yes
05/09/2021	7.88	21.0	Yes
05/10/2021	7.88	21.5	Yes
05/11/2021	7.84	22.5	Yes
05/12/2021	7.77	22.5	Yes
05/13/2021	7.91	23.0	Yes
05/14/2021	7.80	24.0	Yes
05/15/2021	7.79	24.0	Yes
05/16/2021	7.90	24.0	Yes
05/17/2021	7.94	22.0	Yes
05/18/2021	7.97	22.5	Yes
05/19/2021	7.88	22.5	Yes
05/20/2021	7.88	24.0	Yes
05/21/2021	7.86	23.5	Yes
05/22/2021	7.80	22.0	Yes
05/23/2021	7.88	23.0	Yes
05/24/2021	7.85	24.5	Yes
05/25/2021	7.85	24.0	Yes
05/26/2021	7.82	24.0	Yes
05/27/2021	7.91	24.0	Yes
05/28/2021	7.90	23.5	Yes
05/29/2021	7.85	23.0	Yes
05/30/2021	7.88	23.5	Yes
05/31/2021	7.99	25.0	Yes

Number of excursions this month = 0  
 Number of excursions last 5 months = 0

Is System in Compliance?

(Y/N)

Supervisor's Signature

*Bret Bienerth*

Print Name

Bret Bienerth

Certification #:

08749

Phone (503) 635-0394

07-Jun-21