

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form  
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: June 2021

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
06/01/2021	7.88	24.0	Yes
06/02/2021	7.85	25.0	Yes
06/03/2021	7.88	25.5	Yes
06/04/2021	7.82	24.0	Yes
06/05/2021	7.85	25.5	Yes
06/06/2021	7.84	26.0	Yes
06/07/2021	7.81	26.0	Yes
06/08/2021	7.82	26.5	Yes
06/09/2021	7.82	25.3	Yes
06/10/2021	7.82	26.0	Yes
06/11/2021	7.86	27.0	Yes
06/12/2021	7.82	27.5	Yes
06/13/2021	7.87	26.0	Yes
06/14/2021	7.82	26.5	Yes
06/15/2021	7.85	25.5	Yes
06/16/2021	7.82	27.0	Yes
06/17/2021	7.82	27.0	Yes
06/18/2021	7.80	27.5	Yes
06/19/2021	7.84	28.0	Yes
06/20/2021	7.81	28.0	Yes
06/21/2021	7.79	26.0	Yes
06/22/2021	7.83	25.0	Yes
06/23/2021	7.86	29.5	Yes
06/24/2021	7.85	30.0	Yes
06/25/2021	7.80	30.0	Yes
06/26/2021	7.82	29.0	Yes
06/27/2021	7.81	28.5	Yes
06/28/2021	7.81	30.5	Yes
06/29/2021	7.84	30.0	Yes
06/30/2021	7.89	31.0	Yes

Number of excursions this month = 0  
Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature Bret Bienert Print Name Bret Bienert

Certification #: 08749 Phone (503) 635-0394 01-Jul-21