

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: July 2021

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
07/01/2021	7.90	29.7	Yes
07/02/2021	7.93	30.0	Yes
07/03/2021	7.93	30.0	Yes
07/04/2021	7.94	30.0	Yes
07/05/2021	7.97	31.5	Yes
07/06/2021	7.95	32.0	Yes
07/07/2021	7.92	31.3	Yes
07/08/2021	7.92	31.5	Yes
07/09/2021	7.90	31.5	Yes
07/10/2021	7.86	32.0	Yes
07/11/2021	7.93	32.0	Yes
07/12/2021	7.94	34.0	Yes
07/13/2021	7.95	32.0	Yes
07/14/2021	7.93	32.0	Yes
07/15/2021	7.81	33.0	Yes
07/16/2021	7.85	32.5	Yes
07/17/2021	7.92	33.0	Yes
07/18/2021	7.99	38.0	Yes
07/19/2021	7.99	33.0	Yes
07/20/2021	8.01	33.0	Yes
07/21/2021	7.94	33.0	Yes
07/22/2021	7.93	33.0	Yes
07/23/2021	7.93	32.0	Yes
07/24/2021	7.89	32.3	Yes
07/25/2021	7.97	34.5	Yes
07/26/2021	7.93	32.5	Yes
07/27/2021	7.92	35.0	Yes
07/28/2021	7.84	33.0	Yes
07/29/2021	7.85	33.0	Yes
07/30/2021	7.86	33.5	Yes
07/31/2021	7.83	33.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y/N

Supervisor's Signature Bret Bienenrth

Print Name Bret Bienenrth

Certification #: 08749 Phone (503) 635-0394

04-Aug-21