

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: September 2021

**State Minimum = 7.2 pH**

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
09/01/2021	7.89	33.0	Yes
09/02/2021	7.91	34.0	Yes
09/03/2021	7.93	32.5	Yes
09/04/2021	7.88	33.0	Yes
09/05/2021	7.73	32.0	Yes
09/06/2021	7.88	32.0	Yes
09/07/2021	7.81	34.0	Yes
09/08/2021	7.92	32.5	Yes
09/09/2021	7.84	32.0	Yes
09/10/2021	7.93	32.5	Yes
09/11/2021	8.48	32.5	Yes
09/12/2021	8.37	32.0	Yes
09/13/2021	7.91	32.0	Yes
09/14/2021	7.80	32.0	Yes
09/15/2021	7.84	32.0	Yes
09/16/2021	7.92	32.5	Yes
09/17/2021	7.91	30.0	Yes
09/18/2021	7.82	32.0	Yes
09/19/2021	7.80	31.5	Yes
09/20/2021	7.80	30.0	Yes
09/21/2021	7.84	31.5	Yes
09/22/2021	7.86	31.5	Yes
09/23/2021	7.83	32.0	Yes
09/24/2021	7.91	30.5	Yes
09/25/2021	7.87	29.5	Yes
09/26/2021	7.94	28.5	Yes
09/27/2021	7.78	31.5	Yes
09/28/2021	7.75	30.0	Yes
09/29/2021	7.73	29.5	Yes
09/30/2021	7.77	31.5	Yes

Number of excursions this month = 0  
 Number of excursions last 5 months = 0

Is System in Compliance?

(Y/N)

Supervisor's Signature *Bret Bienerth*

Print Name Bret Bienerth

Certification #: 08749

Phone (503) 635-0394

01-Oct-21