

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: October 2021

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
10/01/2021	7.83	30.5	Yes
10/02/2021	7.91	30.0	Yes
10/03/2021	7.87	28.5	Yes
10/04/2021	7.79	29.0	Yes
10/05/2021	7.80	29.5	Yes
10/06/2021	7.81	28.5	Yes
10/07/2021	7.82	30.0	Yes
10/08/2021	7.85	29.5	Yes
10/09/2021	7.89	30.0	Yes
10/10/2021	7.90	30.5	Yes
10/11/2021	7.94	30.0	Yes
10/12/2021	7.91	30.0	Yes
10/13/2021	7.89	30.0	Yes
10/14/2021	7.87	29.5	Yes
10/15/2021	7.84	29.5	Yes
10/16/2021	7.87	28.5	Yes
10/17/2021	7.92	29.5	Yes
10/18/2021	7.86	29.5	Yes
10/19/2021	7.81	29.0	Yes
10/20/2021	7.79	28.5	Yes
10/21/2021	7.86	29.5	Yes
10/22/2021	7.92	30.0	Yes
10/23/2021	7.84	29.0	Yes
10/24/2021	7.91	29.5	Yes
10/25/2021	7.88	29.0	Yes
10/26/2021	7.87	28.5	Yes
10/27/2021	7.83	29.5	Yes
10/28/2021	7.78	27.0	Yes
10/29/2021	7.77	26.0	Yes
10/30/2021	7.77	25.7	Yes
10/31/2021	7.83	23.0	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature

Bret Bienerth

Print Name

Bret Bienerth

Certification #:

08749

Phone (503) 635-0394

02-Nov-21