

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant


Report Month: November 2021

State Minimum = 7.2 pH

| Date | Average Finished pH | Average Finished Alkalinity | Standard Met ? |
|------------|---------------------|-----------------------------|----------------|
| 11/01/2021 | 7.79 | 21.5 | Yes |
| 11/02/2021 | 7.74 | 22.0 | Yes |
| 11/03/2021 | 7.79 | 26.0 | Yes |
| 11/04/2021 | 7.85 | 23.0 | Yes |
| 11/05/2021 | 7.84 | 24.0 | Yes |
| 11/06/2021 | 7.82 | 25.5 | Yes |
| 11/07/2021 | 7.81 | 24.0 | Yes |
| 11/08/2021 | 7.87 | 24.0 | Yes |
| 11/09/2021 | 7.86 | 23.0 | Yes |
| 11/10/2021 | 7.76 | 24.0 | Yes |
| 11/11/2021 | 7.77 | 23.5 | Yes |
| 11/12/2021 | 7.77 | 22.7 | Yes |
| 11/13/2021 | 7.90 | 21.0 | Yes |
| 11/14/2021 | 7.90 | 18.0 | Yes |
| 11/15/2021 | 7.74 | 19.0 | Yes |
| 11/16/2021 | 7.84 | 19.5 | Yes |
| 11/17/2021 | 7.84 | 21.0 | Yes |
| 11/18/2021 | 7.80 | 23.0 | Yes |
| 11/19/2021 | 7.85 | 23.0 | Yes |
| 11/20/2021 | 7.82 | 23.0 | Yes |
| 11/21/2021 | 7.88 | 21.5 | Yes |
| 11/22/2021 | 7.86 | 24.0 | Yes |
| 11/23/2021 | 7.89 | 23.0 | Yes |
| 11/24/2021 | 7.86 | 23.0 | Yes |
| 11/25/2021 | 7.87 | 23.0 | Yes |
| 11/26/2021 | 7.86 | 23.5 | Yes |
| 11/27/2021 | 7.84 | 24.0 | Yes |
| 11/28/2021 | 7.89 | 23.5 | Yes |
| 11/29/2021 | 7.81 | 24.0 | Yes |
| 11/30/2021 | 7.83 | 22.0 | Yes |

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y / N

Supervisor's Signature 

Print Name Bret Bienerth

Certification #: 08749

Phone (503) 635-0394

03-Dec-21