

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: December 2021

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
12/01/2021	7.82	22.0	Yes
12/02/2021	7.91	22.0	Yes
12/03/2021	7.88	23.0	Yes
12/04/2021	7.86	22.7	Yes
12/05/2021	7.99	23.5	Yes
12/06/2021	7.85	24.0	Yes
12/07/2021	7.82	24.0	Yes
12/08/2021	7.87	20.0	Yes
12/09/2021	7.80	23.0	Yes
12/10/2021	7.87	22.0	Yes
12/11/2021	7.89	22.5	Yes
12/12/2021	7.82	21.0	Yes
12/13/2021	7.79	21.5	Yes
12/14/2021	7.81	21.0	Yes
12/15/2021	7.82	21.0	Yes
12/16/2021	7.88	22.0	Yes
12/17/2021	7.89	22.0	Yes
12/18/2021	7.89	22.0	Yes
12/19/2021	7.80	21.5	Yes
12/20/2021	7.85	20.0	Yes
12/21/2021	7.97	19.5	Yes
12/22/2021	7.97	19.0	Yes
12/23/2021	7.87	19.5	Yes
12/24/2021	7.83	16.5	Yes
12/25/2021	7.91	17.0	Yes
12/26/2021	7.90	20.0	Yes
12/27/2021	7.90	20.5	Yes
12/28/2021	7.91	21.5	Yes
12/29/2021	7.84	21.5	Yes
12/30/2021	7.88	22.0	Yes
12/31/2021	7.85	22.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature

Bret Bienerth

Print Name

Bret Bienerth

Certification #:

08749

Phone (503) 635-0394

03-Jan-22