

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form  
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: January 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
01/01/2022	7.83	22.0	Yes
01/02/2022	7.79	23.0	Yes
01/03/2022	7.75	20.5	Yes
01/04/2022	7.94	20.0	Yes
01/05/2022	7.92	22.0	Yes
01/06/2022	7.80	21.5	Yes
01/07/2022	7.91	18.5	Yes
01/08/2022	7.90	17.5	Yes
01/09/2022	7.79	18.5	Yes
01/10/2022	7.81	19.0	Yes
01/11/2022	7.77	20.0	Yes
01/12/2022	7.84	20.0	Yes
01/13/2022	7.87	22.5	Yes
01/14/2022	7.86	20.5	Yes
01/15/2022	7.84	21.5	Yes
01/16/2022	7.78	20.0	Yes
01/17/2022	7.90	21.5	Yes
01/18/2022	8.03	22.0	Yes
01/19/2022	7.98	22.5	Yes
01/20/2022	7.88	22.5	Yes
01/21/2022	7.88	20.5	Yes
01/22/2022	7.86	19.5	Yes
01/23/2022	7.87	20.0	Yes
01/24/2022	7.88	20.5	Yes
01/25/2022	7.90	21.5	Yes
01/26/2022	7.86	22.0	Yes
01/27/2022	7.87	22.5	Yes
01/28/2022	7.77	22.5	Yes
01/29/2022	7.75	21.0	Yes
01/30/2022	7.81	22.0	Yes
01/31/2022	7.85	22.5	Yes

Number of excursions this month = 0  
 Number of excursions last 5 months = 0

Is System in Compliance?  Y  N

Supervisor's Signature *Bret Bienenrth*

Print Name Bret Bienenrth

Certification #: 08749

Phone (503) 635-0394

04-Feb-22