

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant


Report Month: April 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
04/01/2022	7.83	20.5	Yes
04/02/2022	7.93	22.0	Yes
04/03/2022	7.88	21.0	Yes
04/04/2022	7.90	20.5	Yes
04/05/2022	7.88	21.5	Yes
04/06/2022	7.82	21.0	Yes
04/07/2022	7.90	18.0	Yes
04/08/2022	7.83	20.0	Yes
04/09/2022	7.91	20.5	Yes
04/10/2022	7.87	21.0	Yes
04/11/2022	7.84	20.0	Yes
04/12/2022	7.87	21.5	Yes
04/13/2022	7.95	20.5	Yes
04/14/2022	7.90	22.0	Yes
04/15/2022	7.95	21.0	Yes
04/16/2022	7.89	21.0	Yes
04/17/2022	7.93	21.5	Yes
04/18/2022	7.87	21.5	Yes
04/19/2022	7.90	22.5	Yes
04/20/2022	7.89	22.5	Yes
04/21/2022	7.90	22.5	Yes
04/22/2022	7.90	21.5	Yes
04/23/2022	7.87	22.5	Yes
04/24/2022	7.85	22.0	Yes
04/25/2022	7.89	22.0	Yes
04/26/2022	7.88	22.0	Yes
04/27/2022	7.95	21.5	Yes
04/28/2022	7.89	22.0	Yes
04/29/2022	7.89	22.0	Yes
04/30/2022	7.84	21.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y/N

Supervisor's Signature 

Print Name Bret Bienert

Certification #: 08749

Phone (503) 635-0394

06-May-22