

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant


Report Month: May 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
05/01/2022	7.87	21.5	Yes
05/02/2022	7.96	22.0	Yes
05/03/2022	7.88	21.0	Yes
05/04/2022	8.00	20.0	Yes
05/05/2022	7.97	20.8	Yes
05/06/2022	7.93	21.0	Yes
05/07/2022	7.89	19.0	Yes
05/08/2022	7.86	17.5	Yes
05/09/2022	7.85	19.0	Yes
05/10/2022	7.81	18.5	Yes
05/11/2022	7.82	19.5	Yes
05/12/2022	7.90	19.5	Yes
05/13/2022	7.93	20.5	Yes
05/14/2022	7.88	21.5	Yes
05/15/2022	7.86	20.0	Yes
05/16/2022	7.85	19.5	Yes
05/17/2022	7.90	19.5	Yes
05/18/2022	7.89	20.0	Yes
05/19/2022	7.93	19.0	Yes
05/20/2022	7.84	21.0	Yes
05/21/2022	7.79	20.5	Yes
05/22/2022	7.82	21.0	Yes
05/23/2022	7.82	20.5	Yes
05/24/2022	7.84	21.0	Yes
05/25/2022	7.82	21.3	Yes
05/26/2022	7.84	22.5	Yes
05/27/2022	7.88	21.5	Yes
05/28/2022	7.85	22.0	Yes
05/29/2022	7.91	21.0	Yes
05/30/2022	7.81	20.0	Yes
05/31/2022	7.86	20.0	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y / N

Supervisor's Signature 

Print Name Bret Bienenrth

Certification #: 08749

Phone (503) 635-0394

06-Jun-22