

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: June 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
06/01/2022	7.91	21.0	Yes
06/02/2022	7.79	20.0	Yes
06/03/2022	7.81	21.0	Yes
06/04/2022	7.90	22.0	Yes
06/05/2022	7.84	21.0	Yes
06/06/2022	7.80	21.5	Yes
06/07/2022	7.83	22.0	Yes
06/08/2022	7.87	21.5	Yes
06/09/2022	7.93	21.0	Yes
06/10/2022	8.10	21.5	Yes
06/11/2022	8.12	21.5	Yes
06/12/2022	8.05	19.0	Yes
06/13/2022	7.87	19.0	Yes
06/14/2022	7.86	19.5	Yes
06/15/2022	7.83	20.0	Yes
06/16/2022	7.90	19.0	Yes
06/17/2022	7.80	19.0	Yes
06/18/2022	7.86	20.5	Yes
06/19/2022	7.85	21.0	Yes
06/20/2022	7.88	21.5	Yes
06/21/2022	7.90	21.5	Yes
06/22/2022	7.88	21.0	Yes
06/23/2022	7.84	21.5	Yes
06/24/2022	7.81	21.5	Yes
06/25/2022	7.91	22.0	Yes
06/26/2022	7.87	22.5	Yes
06/27/2022	7.81	23.0	Yes
06/28/2022	7.89	23.5	Yes
06/29/2022	8.03	23.5	Yes
06/30/2022	8.05	25.0	Yes

Number of excursions this month =

0


Number of excursions last 5 months =

0

Is System in Compliance?

Y/N

Supervisor's Signature



Print Name

Bret Bienenrth

Certification #:

08749

Phone (503) 635-0394

05-Jul-22