

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: July 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
07/01/2022	8.00	27.0	Yes
07/02/2022	7.92	24.5	Yes
07/03/2022	7.99	25.5	Yes
07/04/2022	8.02	25.5	Yes
07/05/2022	7.96	26.5	Yes
07/06/2022	7.92	26.5	Yes
07/07/2022	7.90	27.5	Yes
07/08/2022	7.83	27.5	Yes
07/09/2022	7.84	27.5	Yes
07/10/2022	7.91	27.5	Yes
07/11/2022	7.93	28.0	Yes
07/12/2022	7.92	29.0	Yes
07/13/2022	7.88	28.5	Yes
07/14/2022	7.89	28.5	Yes
07/15/2022	7.88	30.0	Yes
07/16/2022	7.82	28.0	Yes
07/17/2022	7.93	30.0	Yes
07/18/2022	7.95	29.5	Yes
07/19/2022	7.93	30.0	Yes
07/20/2022	7.84	30.5	Yes
07/21/2022	7.89	30.5	Yes
07/22/2022	7.96	30.5	Yes
07/23/2022	7.92	29.0	Yes
07/24/2022	7.91	30.5	Yes
07/25/2022	7.95	30.0	Yes
07/26/2022	7.93	32.0	Yes
07/27/2022	7.90	30.5	Yes
07/28/2022	7.82	32.0	Yes
07/29/2022	7.87	30.5	Yes
07/30/2022	7.87	30.5	Yes
07/31/2022	7.93	30.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature

Bret Bienenrth

Print Name

Bret Bienenrth

Certification #:

08749

Phone (503) 635-0394

01-Aug-22