

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: August 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
08/01/2022	8.01	32.0	Yes
08/02/2022	7.97	31.5	Yes
08/03/2022	7.92	31.5	Yes
08/04/2022	7.95	31.0	Yes
08/05/2022	7.94	31.5	Yes
08/06/2022	7.92	31.0	Yes
08/07/2022	8.00	32.0	Yes
08/08/2022	8.06	32.0	Yes
08/09/2022	7.98	32.0	Yes
08/10/2022	7.87	30.5	Yes
08/11/2022	7.90	32.5	Yes
08/12/2022	7.87	31.0	Yes
08/13/2022	7.94	32.0	Yes
08/14/2022	7.91	31.5	Yes
08/15/2022	7.90	34.0	Yes
08/16/2022	7.89	32.0	Yes
08/17/2022	7.86	32.5	Yes
08/18/2022	7.87	32.5	Yes
08/19/2022	7.92	32.0	Yes
08/20/2022	7.92	32.5	Yes
08/21/2022	7.91	32.0	Yes
08/22/2022	7.89	32.0	Yes
08/23/2022	7.93	32.5	Yes
08/24/2022	7.94	32.5	Yes
08/25/2022	7.86	32.0	Yes
08/26/2022	7.88	32.0	Yes
08/27/2022	7.89	32.5	Yes
08/28/2022	7.91	33.0	Yes
08/29/2022	7.97	32.5	Yes
08/30/2022	7.88	33.0	Yes
08/31/2022	7.87	32.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y/N

Supervisor's Signature Bret Bienerth Print Name Bret Bienerth

Certification #: 08749 Phone (503) 635-0394 01-Sep-22