

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form  
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: September 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
09/01/2022	7.90	33.5	Yes
09/02/2022	7.87	32.0	Yes
09/03/2022	7.90	33.0	Yes
09/04/2022	7.95	32.5	Yes
09/05/2022	8.00	33.5	Yes
09/06/2022	7.94	34.0	Yes
09/07/2022	7.95	33.5	Yes
09/08/2022	7.98	32.5	Yes
09/09/2022	8.03	32.5	Yes
09/10/2022	7.96	32.5	Yes
09/11/2022	7.95	32.5	Yes
09/12/2022	7.91	32.5	Yes
09/13/2022	7.90	34.0	Yes
09/14/2022	7.93	32.5	Yes
09/15/2022	7.92	34.0	Yes
09/16/2022	7.92	34.0	Yes
09/17/2022	7.90	32.5	Yes
09/18/2022	7.93	33.5	Yes
09/19/2022	7.89	33.0	Yes
09/20/2022	7.93	33.5	Yes
09/21/2022	7.89	33.5	Yes
09/22/2022	7.92	32.5	Yes
09/23/2022	7.89	32.5	Yes
09/24/2022	7.87	32.5	Yes
09/25/2022	7.87	33.0	Yes
09/26/2022	7.86	33.0	Yes
09/27/2022	7.85	32.5	Yes
09/28/2022	7.84	32.5	Yes
09/29/2022	7.84	32.5	Yes
09/30/2022	7.82	32.5	Yes

Number of excursions this month = 0  
 Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature

*Bret Bienerth*

Print Name

Bret Bienerth

Certification #:

08749

Phone (503) 635-0394

04-Oct-22