

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: October 2022

**State Minimum = 7.2 pH**

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
10/01/2022	7.82	32.5	Yes
10/02/2022	7.80	33.5	Yes
10/03/2022	7.85	32.5	Yes
10/04/2022	7.82	33.0	Yes
10/05/2022	7.85	34.0	Yes
10/06/2022	7.83	32.5	Yes
10/07/2022	7.80	32.5	Yes
10/08/2022	7.79	32.0	Yes
10/09/2022	7.83	33.0	Yes
10/10/2022	7.88	32.5	Yes
10/11/2022	7.84	32.5	Yes
10/12/2022	7.85	32.5	Yes
10/13/2022	7.85	33.0	Yes
10/14/2022	7.84	32.0	Yes
10/15/2022	7.83	33.0	Yes
10/16/2022	7.85	32.5	Yes
10/17/2022	7.81	31.0	Yes
10/18/2022	7.85	31.0	Yes
10/19/2022	7.86	29.5	Yes
10/20/2022	7.88	33.0	Yes
10/21/2022	7.88	33.0	Yes
10/22/2022	7.83	33.0	Yes
10/23/2022	7.82	31.5	Yes
10/24/2022	7.82	32.0	Yes
10/25/2022	7.86	30.5	Yes
10/26/2022	7.80	31.0	Yes
10/27/2022	7.82	30.0	Yes
10/28/2022	7.79	29.0	Yes
10/29/2022	7.81	29.5	Yes
10/30/2022	7.81	29.0	Yes
10/31/2022	7.88	28.0	Yes

Number of excursions this month = 0  
 Number of excursions last 5 months = 0

Is System in Compliance?

(Y) N

Supervisor's Signature

*Bret Bienenrth*

Print Name

Bret Bienenrth

Certification #:

08749

Phone (503) 635-0394

02-Nov-22