

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: November 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
11/01/2022	7.87	29.5	Yes
11/02/2022	7.95	28.0	Yes
11/03/2022	7.84	26.0	Yes
11/04/2022	7.82	28.0	Yes
11/05/2022	7.87	26.0	Yes
11/06/2022	7.80	15.0	Yes
11/07/2022	7.98	16.5	Yes
11/08/2022	7.86	18.5	Yes
11/09/2022	7.81	19.0	Yes
11/10/2022	7.80	19.0	Yes
11/11/2022	7.88	22.0	Yes
11/12/2022	7.82	22.5	Yes
11/13/2022	7.89	22.5	Yes
11/14/2022	7.91	23.5	Yes
11/15/2022	7.85	23.0	Yes
11/16/2022	7.84	23.0	Yes
11/17/2022	7.89	24.5	Yes
11/18/2022	7.91	24.5	Yes
11/19/2022	7.83	25.5	Yes
11/20/2022	7.82	25.0	Yes
11/21/2022	7.88	25.0	Yes
11/22/2022	7.92	27.0	Yes
11/23/2022	7.85	27.5	Yes
11/24/2022	7.87	27.0	Yes
11/25/2022	7.83	26.5	Yes
11/26/2022	7.87	27.0	Yes
11/27/2022	7.88	27.0	Yes
11/28/2022	7.98	27.5	Yes
11/29/2022	7.98	24.0	Yes
11/30/2022	7.90	24.5	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature

Bret Bienert

Print Name

Bret Bienert

Certification #:

08749

Phone (503) 635-0394

02-Dec-22