

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: December 2022

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
12/01/2022	7.86	23.7	Yes
12/02/2022	7.83	22.5	Yes
12/03/2022	7.91	22.0	Yes
12/04/2022	8.01	21.0	Yes
12/05/2022	7.83	22.0	Yes
12/06/2022	7.78	22.0	Yes
12/07/2022	8.22	23.0	Yes
12/08/2022	7.92	25.0	Yes
12/09/2022	7.88	24.5	Yes
12/10/2022	7.85	24.5	Yes
12/11/2022	7.89	23.0	Yes
12/12/2022	7.95	24.0	Yes
12/13/2022	7.86	23.0	Yes
12/14/2022	7.90	23.5	Yes
12/15/2022	7.85	24.0	Yes
12/16/2022	7.84	23.0	Yes
12/17/2022	7.85	24.0	Yes
12/18/2022	7.88	23.0	Yes
12/19/2022	7.93	23.5	Yes
12/20/2022	7.99	24.0	Yes
12/21/2022	7.85	23.5	Yes
12/22/2022	7.91	24.0	Yes
12/23/2022	7.95	23.0	Yes
12/24/2022	7.81	24.0	Yes
12/25/2022	7.83	21.5	Yes
12/26/2022	8.00	20.0	Yes
12/27/2022	7.96	17.5	Yes
12/28/2022	7.90	16.5	Yes
12/29/2022	7.89	16.5	Yes
12/30/2022	7.94	18.0	Yes
12/31/2022	7.90	18.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? Y / N

Supervisor's Signature _____ Print Name Bret Bienerth

Certification #: 08749 Phone (503) 635-0394 04-Jan-23