

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant


Report Month: January 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
01/01/2023	7.87	19.0	Yes
01/02/2023	7.87	20.0	Yes
01/03/2023	7.97	20.5	Yes
01/04/2023	8.02	21.0	Yes
01/05/2023	7.95	21.5	Yes
01/06/2023	7.83	21.0	Yes
01/07/2023	7.74	21.5	Yes
01/08/2023	7.91	21.0	Yes
01/09/2023	7.95	21.5	Yes
01/10/2023	7.97	22.5	Yes
01/11/2023	7.86	23.5	Yes
01/12/2023	7.84	22.5	Yes
01/13/2023	7.87	22.5	Yes
01/14/2023	7.91	22.5	Yes
01/15/2023	7.85	21.5	Yes
01/16/2023	7.88	22.0	Yes
01/17/2023	7.94	22.0	Yes
01/18/2023	7.92	22.5	Yes
01/19/2023	7.91	22.5	Yes
01/20/2023	7.86	21.0	Yes
01/21/2023	7.86	21.0	Yes
01/22/2023	7.91	22.0	Yes
01/23/2023	7.96	23.5	Yes
01/24/2023	7.90	24.0	Yes
01/25/2023	7.92	25.0	Yes
01/26/2023	7.86	24.5	Yes
01/27/2023	7.87	25.0	Yes
01/28/2023	7.93	24.0	Yes
01/29/2023	8.04	24.0	Yes
01/30/2023	7.98	24.5	Yes
01/31/2023	7.97	25.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y/N

Supervisor's Signature 

Print Name Bret Bienerth

Certification #: 08749

Phone (503) 635-0394

03-Feb-23