

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: February 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
02/01/2023	8.00	24.5	Yes
02/02/2023	7.97	25.5	Yes
02/03/2023	7.92	23.0	Yes
02/04/2023	7.95	25.5	Yes
02/05/2023	8.08	24.0	Yes
02/06/2023	8.06	24.0	Yes
02/07/2023	8.01	24.0	Yes
02/08/2023	7.98	23.5	Yes
02/09/2023	8.05	24.5	Yes
02/10/2023	7.99	23.0	Yes
02/11/2023	7.98	21.0	Yes
02/12/2023	7.93	22.0	Yes
02/13/2023	7.94	22.0	Yes
02/14/2023	8.00	21.0	Yes
02/15/2023	8.14	23.0	Yes
02/16/2023	8.01	24.0	Yes
02/17/2023	7.92	24.0	Yes
02/18/2023	7.95	23.5	Yes
02/19/2023	8.06	23.0	Yes
02/20/2023	8.11	24.0	Yes
02/21/2023	8.15	24.5	Yes
02/22/2023	7.99	24.0	Yes
02/23/2023	7.99	24.0	Yes
02/24/2023	8.04	24.0	Yes
02/25/2023	7.99	24.0	Yes
02/26/2023	8.01	23.5	Yes
02/27/2023	8.02	25.0	Yes
02/28/2023	8.08	24.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance?

(Y)/N

Supervisor's Signature



Print Name

Bret Bienerth

Certification #:

08749

Phone (503) 635-0394

01-Mar-23