

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form  
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: March 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
03/01/2023	8.05	24.5	Yes
03/02/2023	8.03	23.0	Yes
03/03/2023	8.00	22.0	Yes
03/04/2023	8.01	24.0	Yes
03/05/2023	7.99	24.0	Yes
03/06/2023	8.04	24.0	Yes
03/07/2023	8.07	25.0	Yes
03/08/2023	8.07	24.0	Yes
03/09/2023	7.94	24.5	Yes
03/10/2023	7.95	23.0	Yes
03/11/2023	7.96	24.5	Yes
03/12/2023	7.97	24.0	Yes
03/13/2023	8.06	26.0	Yes
03/14/2023	8.04	24.0	Yes
03/15/2023	7.96	24.0	Yes
03/16/2023	7.94	23.0	Yes
03/17/2023	7.89	22.0	Yes
03/18/2023	7.87	22.5	Yes
03/19/2023	7.86	20.5	Yes
03/20/2023	7.96	24.0	Yes
03/21/2023	8.00	24.0	Yes
03/22/2023	7.95	23.5	Yes
03/23/2023	7.91	23.0	Yes
03/24/2023	7.86	23.0	Yes
03/25/2023	7.86	22.0	Yes
03/26/2023	7.95	23.0	Yes
03/27/2023	7.94	22.0	Yes
03/28/2023	8.01	20.5	Yes
03/29/2023	8.06	22.5	Yes
03/30/2023	7.88	23.0	Yes
03/31/2023	7.88	22.0	Yes

Number of excursions this month = 0  
Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature Bret Bienert

Print Name Bret Bienert

Certification #: 08749

Phone (503) 635-0394

03-Apr-23