

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: April 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
04/01/2023	7.92	23.0	Yes
04/02/2023	7.97	23.5	Yes
04/03/2023	7.91	21.0	Yes
04/04/2023	7.93	21.5	Yes
04/05/2023	7.85	20.5	Yes
04/06/2023	7.94	21.0	Yes
04/07/2023	7.87	22.8	Yes
04/08/2023	7.82	22.0	Yes
04/09/2023	7.89	23.0	Yes
04/10/2023	7.82	20.5	Yes
04/11/2023	7.84	22.0	Yes
04/12/2023	7.77	18.3	Yes
04/13/2023	7.88	18.5	Yes
04/14/2023	7.91	18.5	Yes
04/15/2023	7.86	19.5	Yes
04/16/2023	7.95	20.5	Yes
04/17/2023	8.01	22.0	Yes
04/18/2023	7.92	22.0	Yes
04/19/2023	7.98	21.0	Yes
04/20/2023	7.89	23.0	Yes
04/21/2023	8.02	23.0	Yes
04/22/2023	7.93	22.0	Yes
04/23/2023	7.97	21.5	Yes
04/24/2023	8.02	21.5	Yes
04/25/2023	7.78	21.0	Yes
04/26/2023	7.91	20.0	Yes
04/27/2023	8.02	20.0	Yes
04/28/2023	8.05	20.0	Yes
04/29/2023	8.05	20.0	Yes
04/30/2023	8.04	18.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

Y N

Supervisor's Signature

Bret Bienert

Print Name

Bret Bienert

Certification #:

08749

Phone (503) 635-0394

01-May-23