

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: May 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
05/01/2023	8.03	18.5	Yes
05/02/2023	7.95	17.5	Yes
05/03/2023	7.99	18.0	Yes
05/04/2023	7.97	18.5	Yes
05/05/2023	7.99	19.5	Yes
05/06/2023	7.92	18.0	Yes
05/07/2023	8.10	19.0	Yes
05/08/2023	8.07	19.5	Yes
05/09/2023	8.09	20.0	Yes
05/10/2023	7.85	20.0	Yes
05/11/2023	7.99	19.8	Yes
05/12/2023	7.95	20.5	Yes
05/13/2023	7.92	20.0	Yes
05/14/2023	8.01	20.0	Yes
05/15/2023	7.95	18.5	Yes
05/16/2023	7.99	18.0	Yes
05/17/2023	7.90	18.0	Yes
05/18/2023	8.02	19.0	Yes
05/19/2023	7.94	19.3	Yes
05/20/2023	7.85	18.0	Yes
05/21/2023	7.83	17.5	Yes
05/22/2023	7.88	18.5	Yes
05/23/2023	7.78	17.5	Yes
05/24/2023	7.91	20.0	Yes
05/25/2023	7.96	19.5	Yes
05/26/2023	7.88	21.3	Yes
05/27/2023	7.90	21.0	Yes
05/28/2023	8.04	22.0	Yes
05/29/2023	7.99	22.0	Yes
05/30/2023	7.86	22.5	Yes
05/31/2023	7.93	23.0	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance?

Y/N

Supervisor's Signature

Bret Bienert

Print Name

Bret Bienert

Certification #:

08749

Phone (503) 635-0394

05-Jun-23