

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: June 2023

### State Minimum = 7.2 pH


Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
06/01/2023	7.99	22.8	Yes
06/02/2023	7.91	23.0	Yes
06/03/2023	7.96	23.5	Yes
06/04/2023	7.99	23.5	Yes
06/05/2023	8.03	23.5	Yes
06/06/2023	8.03	24.5	Yes
06/07/2023	8.02	25.0	Yes
06/08/2023	7.90	26.5	Yes
06/09/2023	7.91	27.0	Yes
06/10/2023	7.97	27.0	Yes
06/11/2023	7.88	25.5	Yes
06/12/2023	7.94	27.0	Yes
06/13/2023	7.86	27.5	Yes
06/14/2023	7.92	29.0	Yes
06/15/2023	7.96	23.5	Yes
06/16/2023	7.95	29.0	Yes
06/17/2023	7.90	28.0	Yes
06/18/2023	7.88	28.5	Yes
06/19/2023	7.88	28.0	Yes
06/20/2023	7.96	27.5	Yes
06/21/2023	7.93	26.8	Yes
06/22/2023	7.92	27.5	Yes
06/23/2023	7.92	27.0	Yes
06/24/2023	7.92	27.3	Yes
06/25/2023	7.92	28.5	Yes
06/26/2023	7.86	29.5	Yes
06/27/2023	7.85	28.5	Yes
06/28/2023	7.91	29.3	Yes
06/29/2023	7.86	30.5	Yes
06/30/2023	7.84	28.8	Yes

Number of excursions this month = 0  
 Number of excursions last 5 months = 0

Is System in Compliance?

(Y) N

Supervisor's Signature



Print Name

Bret Bienert

Certification #:

08749

Phone (503) 635-0394

03-Jul-23