

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant


Report Month: July 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
07/01/2023	7.83	31.0	Yes
07/02/2023	7.79	30.0	Yes
07/03/2023	7.79	30.5	Yes
07/04/2023	7.79	31.0	Yes
07/05/2023	7.78	32.0	Yes
07/06/2023	7.93	32.0	Yes
07/07/2023	7.96	32.0	Yes
07/08/2023	7.88	31.0	Yes
07/09/2023	7.88	31.0	Yes
07/10/2023	7.84	31.3	Yes
07/11/2023	7.91	31.5	Yes
07/12/2023	7.93	31.3	Yes
07/13/2023	8.05	31.0	Yes
07/14/2023	7.94	31.0	Yes
07/15/2023	7.90	32.5	Yes
07/16/2023	7.88	32.0	Yes
07/17/2023	7.83	31.5	Yes
07/18/2023	7.97	31.5	Yes
07/19/2023	7.98	31.5	Yes
07/20/2023	7.95	33.0	Yes
07/21/2023	7.91	33.0	Yes
07/22/2023	7.93	33.0	Yes
07/23/2023	8.01	31.5	Yes
07/24/2023	7.95	31.5	Yes
07/25/2023	8.08	32.0	Yes
07/26/2023	8.04	31.5	Yes
07/27/2023	8.07	32.8	Yes
07/28/2023	8.02	32.5	Yes
07/29/2023	8.06	33.0	Yes
07/30/2023	8.04	32.0	Yes
07/31/2023	8.06	31.5	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature 

Print Name Bret Bienert

Certification #: 08749

Phone (503) 635-0394

07-Aug-23