

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: September 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
09/01/2023	7.86	34.0	Yes
09/02/2023	7.89	33.5	Yes
09/03/2023	7.79	33.0	Yes
09/04/2023	7.78	32.5	Yes
09/05/2023	7.81	32.5	Yes
09/06/2023	7.76	32.0	Yes
09/07/2023	7.91	31.8	Yes
09/08/2023	7.86	31.0	Yes
09/09/2023	7.93	34.0	Yes
09/10/2023	7.82	31.5	Yes
09/11/2023	7.95	33.0	Yes
09/12/2023	7.93	33.0	Yes
09/13/2023	7.90	33.5	Yes
09/14/2023	7.84	32.5	Yes
09/15/2023	7.86	33.5	Yes
09/16/2023	7.85	32.5	Yes
09/17/2023	7.85	33.5	Yes
09/18/2023	7.84	34.0	Yes
09/19/2023	7.84	34.5	Yes
09/20/2023	7.94	34.0	Yes
09/21/2023	7.94	32.8	Yes
09/22/2023	7.97	32.5	Yes
09/23/2023	7.96	32.5	Yes
09/24/2023	7.84	32.5	Yes
09/25/2023	7.87	33.0	Yes
09/26/2023	7.95	32.0	Yes
09/27/2023	7.90	32.5	Yes
09/28/2023	7.81	33.0	Yes
09/29/2023	7.84	32.0	Yes
09/30/2023	7.81	34.0	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? YN

Supervisor's Signature  Print Name Bret Bienert

Certification #: 08749 Phone (503) 635-0394 02-Oct-23