

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant


Report Month: October 2023

**State Minimum = 7.2 pH**

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
10/01/2023	7.82	32.5	Yes
10/02/2023	7.78	32.5	Yes
10/03/2023	7.87	32.0	Yes
10/04/2023	7.83	31.0	Yes
10/05/2023	7.87	30.5	Yes
10/06/2023	7.86	32.0	Yes
10/07/2023	7.88	31.5	Yes
10/08/2023	7.81	31.5	Yes
10/09/2023	7.73	33.5	Yes
10/10/2023	7.86	31.8	Yes
10/11/2023	7.87	32.5	Yes
10/12/2023	7.88	30.5	Yes
10/13/2023	7.82	30.0	Yes
10/14/2023	7.87	32.0	Yes
10/15/2023	7.76	30.5	Yes
10/16/2023	7.76	29.5	Yes
10/17/2023	7.83	29.5	Yes
10/18/2023	7.81	27.5	Yes
10/19/2023	7.83	29.0	Yes
10/20/2023	7.82	29.5	Yes
10/21/2023	7.93	29.0	Yes
10/22/2023	7.87	30.5	Yes
10/23/2023	7.81	31.0	Yes
10/24/2023	7.72	30.0	Yes
10/25/2023	7.83	30.0	Yes
10/26/2023	7.92	30.0	Yes
10/27/2023	7.96	30.0	Yes
10/28/2023	7.91	30.0	Yes
10/29/2023	7.87	29.5	Yes
10/30/2023	7.91	29.5	Yes
10/31/2023	7.92	30.0	Yes

Number of excursions this month = 0  
 Number of excursions last 5 months = 0

Is System in Compliance?  Y  N

Supervisor's Signature 

Print Name Bret Bienert

Certification #: 08749

Phone (503) 635-0394

02-Nov-23