

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: November 2023

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
11/01/2023	8.01	30.0	Yes
11/02/2023	8.05	29.0	Yes
11/03/2023	8.01	28.0	Yes
11/04/2023	7.99	28.5	Yes
11/05/2023	7.92	29.0	Yes
11/06/2023	7.86	26.0	Yes
11/07/2023	7.83	23.0	Yes
11/08/2023	7.91	22.0	Yes
11/09/2023	7.92	20.5	Yes
11/10/2023	7.97	20.5	Yes
11/11/2023	7.94	21.5	Yes
11/12/2023	7.79	21.0	Yes
11/13/2023	7.87	22.0	Yes
11/14/2023	7.85	23.0	Yes
11/15/2023	7.92	22.5	Yes
11/16/2023	7.97	21.0	Yes
11/17/2023	7.89	23.5	Yes
11/18/2023	7.92	23.0	Yes
11/19/2023	7.84	24.0	Yes
11/20/2023	7.74	24.0	Yes
11/21/2023	7.86	24.0	Yes
11/22/2023	7.99	25.0	Yes
11/23/2023	8.04	24.5	Yes
11/24/2023	7.95	24.5	Yes
11/25/2023	7.88	24.5	Yes
11/26/2023	7.90	24.0	Yes
11/27/2023	7.86	24.0	Yes
11/28/2023	7.96	26.0	Yes
11/29/2023	7.87	25.0	Yes
11/30/2023	7.82	25.0	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance? Y / N

Supervisor's Signature _____ Print Name Bret Bienerth

Certification #: 08749 Phone (503) 635-0394 04-Dec-23