

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant


Report Month: January 2024

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
01/01/2024	7.93	24.0	Yes
01/02/2024	7.93	25.0	Yes
01/03/2024	7.94	24.0	Yes
01/04/2024	7.93	23.0	Yes
01/05/2024	7.83	24.3	Yes
01/06/2024	7.88	23.5	Yes
01/07/2024	7.89	23.5	Yes
01/08/2024	7.92	22.5	Yes
01/09/2024	7.94	23.0	Yes
01/10/2024	7.90	22.0	Yes
01/11/2024	7.88	19.5	Yes
01/12/2024	7.81	20.0	Yes
01/13/2024	7.83	21.0	Yes
01/14/2024	7.78	20.5	Yes
01/15/2024	7.83	21.5	Yes
01/16/2024	7.79	23.0	Yes
01/17/2024	7.82	22.5	Yes
01/18/2024	7.86	22.5	Yes
01/19/2024	7.82	18.0	Yes
01/20/2024	8.00	19.0	Yes
01/21/2024	7.91	20.0	Yes
01/22/2024	8.05	20.0	Yes
01/23/2024	8.10	20.0	Yes
01/24/2024	7.87	18.5	Yes
01/25/2024	7.92	16.5	Yes
01/26/2024	7.97	19.0	Yes
01/27/2024	7.89	19.0	Yes
01/28/2024	8.05	18.5	Yes
01/29/2024	8.02	17.5	Yes
01/30/2024	8.05	18.5	Yes
01/31/2024	7.99	18.5	Yes

Number of excursions this month = 0
 Number of excursions last 5 months = 0

Is System in Compliance? Y / N

Supervisor's Signature 

Print Name Dave Trotter

Certification #: 058778

Phone (503) 635-0394

01-Feb-24