

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form
Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: February 2024

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
02/01/2024	7.90	18.5	Yes
02/02/2024	7.93	20.0	Yes
02/03/2024	7.90	18.5	Yes
02/04/2024	7.92	20.0	Yes
02/05/2024	7.94	20.5	Yes
02/06/2024	8.03	21.0	Yes
02/07/2024	8.05	21.5	Yes
02/08/2024	8.06	21.0	Yes
02/09/2024	7.98	21.5	Yes
02/10/2024	7.98	21.5	Yes
02/11/2024	7.98	23.5	Yes
02/12/2024	8.04	24.3	Yes
02/13/2024	8.02	24.0	Yes
02/14/2024	8.00	24.5	Yes
02/15/2024	7.97	24.0	Yes
02/16/2024	7.97	24.0	Yes
02/17/2024	7.96	23.5	Yes
02/18/2024	8.04	24.0	Yes
02/19/2024	8.00	23.5	Yes
02/20/2024	8.01	24.0	Yes
02/21/2024	8.02	24.5	Yes
02/22/2024	7.97	25.0	Yes
02/23/2024	7.99	24.0	Yes
02/24/2024	8.00	24.5	Yes
02/25/2024	8.01	23.5	Yes
02/26/2024	8.08	22.0	Yes
02/27/2024	8.04	22.0	Yes
02/28/2024	8.06	22.0	Yes
02/29/2024	7.92	20.0	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance?

Y / N

Supervisor's Signature



Print Name

Dave Trotter

Certification #:

058778

Phone (503) 635-0394

05-Mar-24