

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: March 2024

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
03/01/2024	7.94	18.5	Yes
03/02/2024	7.98	19.5	Yes
03/03/2024	7.97	20.5	Yes
03/04/2024	7.99	21.0	Yes
03/05/2024	7.87	20.5	Yes
03/06/2024	7.91	22.0	Yes
03/07/2024	7.91	22.0	Yes
03/08/2024	7.90	22.0	Yes
03/09/2024	7.98	23.0	Yes
03/10/2024	7.99	24.0	Yes
03/11/2024	8.02	24.0	Yes
03/12/2024	7.88	25.5	Yes
03/13/2024	7.86	24.0	Yes
03/14/2024	7.92	22.5	Yes
03/15/2024	7.92	22.5	Yes
03/16/2024	7.94	22.0	Yes
03/17/2024	7.95	23.5	Yes
03/18/2024	7.96	23.0	Yes
03/19/2024	7.97	23.0	Yes
03/20/2024	7.86	23.0	Yes
03/21/2024	7.96	22.5	Yes
03/22/2024	7.93	21.8	Yes
03/23/2024	7.95	21.8	Yes
03/24/2024	7.94	21.5	Yes
03/25/2024	7.87	21.5	Yes
03/26/2024	7.89	21.5	Yes
03/27/2024	7.82	21.5	Yes
03/28/2024	7.88	22.0	Yes
03/29/2024	7.94	21.5	Yes
03/30/2024	7.96	20.5	Yes
03/31/2024	7.96	20.0	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature 

Print Name Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Apr-24