

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: April 2024


State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
04/01/2024	7.96	21.5	Yes
04/02/2024	7.94	21.5	Yes
04/03/2024	8.00	21.5	Yes
04/04/2024	7.88	20.5	Yes
04/05/2024	7.88	22.5	Yes
04/06/2024	7.91	22.0	Yes
04/07/2024	7.98	23.0	Yes
04/08/2024	7.97	22.5	Yes
04/09/2024	7.95	22.5	Yes
04/10/2024	7.90	22.0	Yes
04/11/2024	7.91	22.0	Yes
04/12/2024	8.01	22.3	Yes
04/13/2024	8.01	22.5	Yes
04/14/2024	8.04	23.0	Yes
04/15/2024	8.03	22.5	Yes
04/16/2024	8.07	23.0	Yes
04/17/2024	7.94	20.5	Yes
04/18/2024	7.96	21.5	Yes
04/19/2024	8.03	20.5	Yes
04/20/2024	8.06	21.8	Yes
04/21/2024	8.10	22.5	Yes
04/22/2024	8.02	23.0	Yes
04/23/2024	7.96	22.5	Yes
04/24/2024	7.93	22.0	Yes
04/25/2024	7.83	22.3	Yes
04/26/2024	7.97	22.8	Yes
04/27/2024	7.94	23.5	Yes
04/28/2024	7.96	23.0	Yes
04/29/2024	7.98	21.8	Yes
04/30/2024	7.99	21.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature 

Print Name Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-May-24