

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: May 2024

State Minimum = 7.2 pH


Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
05/01/2024	7.93	21.0	Yes
05/02/2024	7.86	20.8	Yes
05/03/2024	7.86	20.5	Yes
05/04/2024	7.89	20.8	Yes
05/05/2024	7.81	20.5	Yes
05/06/2024	7.88	21.5	Yes
05/07/2024	7.80	19.0	Yes
05/08/2024	7.76	21.0	Yes
05/09/2024	7.79	19.5	Yes
05/10/2024	7.88	20.0	Yes
05/11/2024	7.95	20.5	Yes
05/12/2024	7.99	20.0	Yes
05/13/2024	8.03	21.5	Yes
05/14/2024	7.95	20.5	Yes
05/15/2024	7.93	21.0	Yes
05/16/2024	7.90	20.0	Yes
05/17/2024	7.93	22.0	Yes
05/18/2024	7.97	21.8	Yes
05/19/2024	7.96	22.5	Yes
05/20/2024	7.91	22.5	Yes
05/21/2024	7.95	23.0	Yes
05/22/2024	8.02	23.0	Yes
05/23/2024	7.95	22.5	Yes
05/24/2024	7.97	22.5	Yes
05/25/2024	7.93	22.5	Yes
05/26/2024	7.83	23.0	Yes
05/27/2024	7.91	23.0	Yes
05/28/2024	8.07	22.5	Yes
05/29/2024	8.03	22.5	Yes
05/30/2024	8.00	22.8	Yes
05/31/2024	8.06	23.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature



Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Jun-24