

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: June 2024


**State Minimum = 7.2 pH**

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
06/01/2024	8.12	24.3	Yes
06/02/2024	8.15	22.0	Yes
06/03/2024	7.99	24.0	Yes
06/04/2024	8.08	23.5	Yes
06/05/2024	8.04	21.5	Yes
06/06/2024	7.94	20.0	Yes
06/07/2024	8.00	22.0	Yes
06/08/2024	8.06	20.5	Yes
06/09/2024	8.00	21.0	Yes
06/10/2024	8.05	22.0	Yes
06/11/2024	7.97	22.0	Yes
06/12/2024	8.11	24.0	Yes
06/13/2024	7.99	23.5	Yes
06/14/2024	7.91	24.0	Yes
06/15/2024	7.99	25.0	Yes
06/16/2024	8.10	26.0	Yes
06/17/2024	8.18	26.5	Yes
06/18/2024	8.13	26.5	Yes
06/19/2024	8.12	26.5	Yes
06/20/2024	8.04	27.0	Yes
06/21/2024	7.99	26.5	Yes
06/22/2024	7.99	27.0	Yes
06/23/2024	8.05	28.0	Yes
06/24/2024	7.99	27.0	Yes
06/25/2024	7.95	28.0	Yes
06/26/2024	7.92	27.0	Yes
06/27/2024	7.93	28.3	Yes
06/28/2024	7.81	27.5	Yes
06/29/2024	7.78	28.5	Yes
06/30/2024	7.80	28.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?  Y  N

Supervisor's Signature 

Print Name Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Jul-24