

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: July 2024

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
07/01/2024	7.78	27.8	Yes
07/02/2024	7.82	27.5	Yes
07/03/2024	7.83	28.5	Yes
07/04/2024	7.93	29.0	Yes
07/05/2024	8.08	30.5	Yes
07/06/2024	8.08	30.0	Yes
07/07/2024	7.97	29.5	Yes
07/08/2024	7.93	30.0	Yes
07/09/2024	7.90	30.0	Yes
07/10/2024	8.04	30.5	Yes
07/11/2024	8.07	30.8	Yes
07/12/2024	8.10	31.8	Yes
07/13/2024	8.11	30.5	Yes
07/14/2024	8.11	32.0	Yes
07/15/2024	8.17	32.5	Yes
07/16/2024	8.09	32.8	Yes
07/17/2024	8.06	32.0	Yes
07/18/2024	8.05	32.0	Yes
07/19/2024	8.11	32.0	Yes
07/20/2024	8.08	32.5	Yes
07/21/2024	8.10	32.5	Yes
07/22/2024	8.04	31.0	Yes
07/23/2024	8.21	33.0	Yes
07/24/2024	8.14	33.0	Yes
07/25/2024	8.13	32.5	Yes
07/26/2024	8.04	32.0	Yes
07/27/2024	8.08	32.3	Yes
07/28/2024	7.96	32.5	Yes
07/29/2024	8.13	33.0	Yes
07/30/2024	8.16	32.5	Yes
07/31/2024	8.06	32.5	Yes


Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

Y N

Supervisor's Signature



Print Name

Dave Trotter

Certification #:

058778

Phone (503) 635-0394

01-Aug-24