

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: August 2024

**State Minimum = 7.2 pH**

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
08/01/2024	8.02	32.5	Yes
08/02/2024	8.07	32.0	Yes
08/03/2024	8.05	32.0	Yes
08/04/2024	8.01	32.5	Yes
08/05/2024	7.98	32.5	Yes
08/06/2024	7.98	32.5	Yes
08/07/2024	8.06	34.0	Yes
08/08/2024	7.97	32.0	Yes
08/09/2024	7.97	32.5	Yes
08/10/2024	8.01	32.5	Yes
08/11/2024	7.96	33.0	Yes
08/12/2024	8.00	32.5	Yes
08/13/2024	8.03	34.0	Yes
08/14/2024	7.95	33.0	Yes
08/15/2024	7.97	32.0	Yes
08/16/2024	7.97	32.5	Yes
08/17/2024	8.02	33.0	Yes
08/18/2024	7.97	33.8	Yes
08/19/2024	7.94	33.0	Yes
08/20/2024	8.00	32.8	Yes
08/21/2024	8.02	32.5	Yes
08/22/2024	7.87	32.5	Yes
08/23/2024	7.88	32.5	Yes
08/24/2024	7.91	33.8	Yes
08/25/2024	7.95	33.5	Yes
08/26/2024	7.90	32.0	Yes
08/27/2024	7.86	32.5	Yes
08/28/2024	8.00	34.0	Yes
08/29/2024	8.02	33.5	Yes
08/30/2024	7.89	33.0	Yes
08/31/2024	7.87	32.5	Yes


Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

Y  N

Supervisor's Signature



Print Name

Dave Trotter

Certification #:

058778

Phone (503) 635-0394

07-Sep-24