

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: September 2024

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
09/01/2024	7.77	33.5	Yes
09/02/2024	7.82	33.5	Yes
09/03/2024	7.92	34.5	Yes
09/04/2024	7.98	33.0	Yes
09/05/2024	7.80	32.5	Yes
09/06/2024	7.89	32.0	Yes
09/07/2024	7.88	32.3	Yes
09/08/2024	7.90	33.5	Yes
09/09/2024	8.02	33.5	Yes
09/10/2024	7.89	33.0	Yes
09/11/2024	7.89	33.5	Yes
09/12/2024	7.92	32.5	Yes
09/13/2024	7.93	32.5	Yes
09/14/2024	7.94	33.5	Yes
09/15/2024	7.93	33.0	Yes
09/16/2024	7.96	33.0	Yes
09/17/2024	7.89	34.0	Yes
09/18/2024	7.94	32.5	Yes
09/19/2024	7.92	32.5	Yes
09/20/2024	7.87	33.0	Yes
09/21/2024	7.90	32.5	Yes
09/22/2024	7.89	33.5	Yes
09/23/2024	7.95	33.5	Yes
09/24/2024	7.92	32.5	Yes
09/25/2024	7.92	33.5	Yes
09/26/2024	7.89	33.0	Yes
09/27/2024	7.99	32.5	Yes
09/28/2024	7.89	33.0	Yes
09/29/2024	7.91	33.0	Yes
09/30/2024	7.90	33.0	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

Y N

Supervisor's Signature



Print Name

Dave Trotter

Certification #:

058778

Phone (503) 635-0394

03-Oct-24