

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: October 2024

**State Minimum = 7.2 pH**


Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
10/01/2024	7.88	32.3	Yes
10/02/2024	8.00	34.0	Yes
10/03/2024	8.00	32.5	Yes
10/04/2024	8.01	32.5	Yes
10/05/2024	8.00	32.5	Yes
10/06/2024	7.98	33.5	Yes
10/07/2024	8.03	34.0	Yes
10/08/2024	8.06	33.0	Yes
10/09/2024	8.09	32.5	Yes
10/10/2024	7.90	33.0	Yes
10/11/2024	7.93	32.5	Yes
10/12/2024	7.94	32.5	Yes
10/13/2024	7.92	33.0	Yes
10/14/2024	8.00	34.0	Yes
10/15/2024	7.98	34.0	Yes
10/16/2024	7.92	34.0	Yes
10/17/2024	7.96	33.0	Yes
10/18/2024	7.96	33.5	Yes
10/19/2024	7.97	32.8	Yes
10/20/2024	7.88	34.0	Yes
10/21/2024	7.88	33.5	Yes
10/22/2024	7.91	33.5	Yes
10/23/2024	7.92	32.0	Yes
10/24/2024	7.95	32.0	Yes
10/25/2024	7.97	33.0	Yes
10/26/2024	8.00	32.5	Yes
10/27/2024	7.95	31.5	Yes
10/28/2024	7.87	32.0	Yes
10/29/2024	7.95	32.5	Yes
10/30/2024	7.88	29.5	Yes
10/31/2024	7.98	32.0	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?  Y  N

Supervisor's Signature



Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Nov-24