

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: November 2024


State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
11/01/2024	7.95	30.5	Yes
11/02/2024	7.93	31.0	Yes
11/03/2024	7.92	28.5	Yes
11/04/2024	7.97	26.5	Yes
11/05/2024	7.84	25.0	Yes
11/06/2024	7.88	24.0	Yes
11/07/2024	8.02	22.5	Yes
11/08/2024	7.88	24.0	Yes
11/09/2024	7.91	23.0	Yes
11/10/2024	7.96	24.5	Yes
11/11/2024	7.97	24.5	Yes
11/12/2024	7.92	25.0	Yes
11/13/2024	7.92	25.0	Yes
11/14/2024	8.02	24.5	Yes
11/15/2024	7.87	23.5	Yes
11/16/2024	7.90	22.5	Yes
11/17/2024	7.90	22.0	Yes
11/18/2024	8.00	21.5	Yes
11/19/2024	7.83	20.0	Yes
11/20/2024	7.89	20.0	Yes
11/21/2024	7.88	20.0	Yes
11/22/2024	7.93	20.0	Yes
11/23/2024	7.89	21.5	Yes
11/24/2024	8.00	21.0	Yes
11/25/2024	7.88	20.5	Yes
11/26/2024	7.90	21.5	Yes
11/27/2024	7.89	22.5	Yes
11/28/2024	7.90	23.0	Yes
11/29/2024	7.90	23.0	Yes
11/30/2024	7.85	23.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature 

Print Name Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Dec-24