

# Lake Oswego - Tigard Water Supply, PWS 4101542

## Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

### Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: December 2024


**State Minimum = 7.2 pH**

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
12/01/2024	7.82	23.5	Yes
12/02/2024	7.92	24.0	Yes
12/03/2024	8.09	24.5	Yes
12/04/2024	8.08	25.0	Yes
12/05/2024	8.07	25.5	Yes
12/06/2024	8.10	25.0	Yes
12/07/2024	8.10	25.5	Yes
12/08/2024	8.15	23.5	Yes
12/09/2024	8.11	24.5	Yes
12/10/2024	8.14	24.5	Yes
12/11/2024	8.08	26.0	Yes
12/12/2024	8.13	23.5	Yes
12/13/2024	8.25	24.0	Yes
12/14/2024	7.99	24.0	Yes
12/15/2024	8.01	23.5	Yes
12/16/2024	8.09	23.5	Yes
12/17/2024	8.15	22.5	Yes
12/18/2024	8.15	22.5	Yes
12/19/2024	8.14	22.0	Yes
12/20/2024	8.00	20.5	Yes
12/21/2024	8.02	20.0	Yes
12/22/2024	8.07	20.5	Yes
12/23/2024	7.98	21.3	Yes
12/24/2024	7.98	22.0	Yes
12/25/2024	8.02	20.5	Yes
12/26/2024	7.96	21.0	Yes
12/27/2024	8.04	19.0	Yes
12/28/2024	7.93	18.0	Yes
12/29/2024	7.94	18.5	Yes
12/30/2024	7.96	17.5	Yes
12/31/2024	7.95	19.5	Yes

Number of excursions this month = 0  
Number of excursions last 5 months = 0

Is System in Compliance?  Y  N

Supervisor's Signature



Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Jan-25