

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: January 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
01/01/2025	8.07	20.0	Yes
01/02/2025	8.00	21.0	Yes
01/03/2025	7.99	21.5	Yes
01/04/2025	8.01	21.0	Yes
01/05/2025	7.99	20.0	Yes
01/06/2025	8.01	20.5	Yes
01/07/2025	7.93	21.0	Yes
01/08/2025	7.92	21.0	Yes
01/09/2025	8.08	19.5	Yes
01/10/2025	8.04	23.0	Yes
01/11/2025	8.08	22.5	Yes
01/12/2025	8.06	22.0	Yes
01/13/2025	8.07	23.0	Yes
01/14/2025	8.05	22.0	Yes
01/15/2025	7.97	22.0	Yes
01/16/2025	7.93	22.0	Yes
01/17/2025	7.94	22.5	Yes
01/18/2025	7.98	22.5	Yes
01/19/2025	7.84	23.5	Yes
01/20/2025	8.00	24.0	Yes
01/21/2025	7.99	23.5	Yes
01/22/2025	8.09	25.0	Yes
01/23/2025	8.02	25.0	Yes
01/24/2025	8.00	24.5	Yes
01/25/2025	8.02	25.0	Yes
01/26/2025	8.00	25.0	Yes
01/27/2025	7.97	25.0	Yes
01/28/2025	7.87	25.0	Yes
01/29/2025	8.03	25.5	Yes
01/30/2025	8.00	25.5	Yes
01/31/2025	8.06	26.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature



Print Name

Dave Trotter

Certification #:

058778

Phone (503) 635-0394

03-Feb-25