

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: February 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
02/01/2025	8.11	25.5	Yes
02/02/2025	8.04	26.0	Yes
02/03/2025	8.04	26.5	Yes
02/04/2025	8.03	25.5	Yes
02/05/2025	8.00	23.5	Yes
02/06/2025	7.97	24.0	Yes
02/07/2025	7.91	24.0	Yes
02/08/2025	7.99	24.0	Yes
02/09/2025	8.02	25.5	Yes
02/10/2025	8.02	25.0	Yes
02/11/2025	7.97	25.0	Yes
02/12/2025	8.01	24.0	Yes
02/13/2025	7.97	24.5	Yes
02/14/2025	7.98	25.0	Yes
02/15/2025	7.94	26.0	Yes
02/16/2025	7.93	25.0	Yes
02/17/2025	7.96	24.5	Yes
02/18/2025	8.03	23.0	Yes
02/19/2025	8.02	22.5	Yes
02/20/2025	8.05	22.0	Yes
02/21/2025	8.03	21.5	Yes
02/22/2025	7.95	22.0	Yes
02/23/2025	7.92	20.5	Yes
02/24/2025	7.92	19.0	Yes
02/25/2025	7.95	15.0	Yes
02/26/2025	8.00	18.0	Yes
02/27/2025	8.01	18.0	Yes
02/28/2025	7.96	19.5	Yes

Number of excursions this month =

0


Number of excursions last 5 months =

0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature



Print Name

Dave Trotter

Certification #:

058778

Phone (503) 635-0394

03-Mar-25