

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: March 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
03/01/2025	7.99	20.0	Yes
03/02/2025	8.00	21.5	Yes
03/03/2025	7.94	21.0	Yes
03/04/2025	7.98	21.5	Yes
03/05/2025	8.01	21.5	Yes
03/06/2025	8.06	22.0	Yes
03/07/2025	8.04	22.0	Yes
03/08/2025	7.95	22.0	Yes
03/09/2025	8.01	22.5	Yes
03/10/2025	8.03	22.5	Yes
03/11/2025	8.02	23.5	Yes
03/12/2025	7.93	22.5	Yes
03/13/2025	8.05	23.0	Yes
03/14/2025	8.00	23.0	Yes
03/15/2025	7.99	22.5	Yes
03/16/2025	8.00	22.0	Yes
03/17/2025	8.06	22.5	Yes
03/18/2025	7.97	19.5	Yes
03/19/2025	7.93	21.0	Yes
03/20/2025	7.93	20.5	Yes
03/21/2025	8.01	21.5	Yes
03/22/2025	8.06	22.0	Yes
03/23/2025	8.02	19.5	Yes
03/24/2025	8.01	20.5	Yes
03/25/2025	8.07	20.5	Yes
03/26/2025	8.05	20.5	Yes
03/27/2025	7.88	19.5	Yes
03/28/2025	7.87	19.0	Yes
03/29/2025	7.92	19.0	Yes
03/30/2025	7.96	19.0	Yes
03/31/2025	8.03	19.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature

Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Apr-25