

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: April 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
04/01/2025	7.96	21.0	Yes
04/02/2025	7.99	20.5	Yes
04/03/2025	7.95	20.5	Yes
04/04/2025	7.94	21.0	Yes
04/05/2025	7.93	21.5	Yes
04/06/2025	8.02	22.5	Yes
04/07/2025	8.01	22.0	Yes
04/08/2025	7.92	22.0	Yes
04/09/2025	7.95	22.5	Yes
04/10/2025	7.97	20.0	Yes
04/11/2025	8.05	20.5	Yes
04/12/2025	8.00	20.5	Yes
04/13/2025	8.00	20.0	Yes
04/14/2025	8.00	20.0	Yes
04/15/2025	7.96	20.0	Yes
04/16/2025	8.01	20.0	Yes
04/17/2025	8.03	21.5	Yes
04/18/2025	8.04	21.0	Yes
04/19/2025	8.00	22.0	Yes
04/20/2025	8.01	22.5	Yes
04/21/2025	7.92	21.0	Yes
04/22/2025	8.06	22.0	Yes
04/23/2025	8.06	21.0	Yes
04/24/2025	8.14	22.5	Yes
04/25/2025	8.04	22.5	Yes
04/26/2025	7.98	23.5	Yes
04/27/2025	8.02	22.0	Yes
04/28/2025	8.06	22.0	Yes
04/29/2025	7.96	23.0	Yes
04/30/2025	7.95	22.0	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature _____ Print Name Dave Trotter

Certification #: 058778 Phone (503) 635-0394

03-May-25