

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: May 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
05/01/2025	7.90	22.0	Yes
05/02/2025	7.94	22.5	Yes
05/03/2025	7.85	24.0	Yes
05/04/2025	7.90	24.0	Yes
05/05/2025	7.98	24.0	Yes
05/06/2025	7.97	24.5	Yes
05/07/2025	7.95	24.0	Yes
05/08/2025	8.04	24.0	Yes
05/09/2025	8.02	24.5	Yes
05/10/2025	7.96	25.0	Yes
05/11/2025	7.93	25.5	Yes
05/12/2025	7.97	25.5	Yes
05/13/2025	8.05	25.5	Yes
05/14/2025	8.01	25.5	Yes
05/15/2025	7.95	24.5	Yes
05/16/2025	8.03	25.5	Yes
05/17/2025	8.01	26.0	Yes
05/18/2025	7.85	26.0	Yes
05/19/2025	7.96	24.5	Yes
05/20/2025	7.96	23.5	Yes
05/21/2025	8.06	25.0	Yes
05/22/2025	7.97	25.0	Yes
05/23/2025	8.11	20.0	Yes
05/24/2025	8.12	24.0	Yes
05/25/2025	8.13	23.5	Yes
05/26/2025	8.11	23.5	Yes
05/27/2025	8.00	24.5	Yes
05/28/2025	8.15	24.0	Yes
05/29/2025	8.07	25.5	Yes
05/30/2025	7.97	24.0	Yes
05/31/2025	7.99	26.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature

Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Jun-25