

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: June 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
06/01/2025	7.83	25.0	Yes
06/02/2025	7.86	26.5	Yes
06/03/2025	7.93	26.0	Yes
06/04/2025	7.91	26.5	Yes
06/05/2025	7.90	27.5	Yes
06/06/2025	7.93	28.0	Yes
06/07/2025	7.92	28.5	Yes
06/08/2025	7.98	29.5	Yes
06/09/2025	7.91	30.0	Yes
06/10/2025	7.95	30.0	Yes
06/11/2025	7.87	29.0	Yes
06/12/2025	7.89	28.5	Yes
06/13/2025	7.93	28.0	Yes
06/14/2025	7.96	28.5	Yes
06/15/2025	7.96	30.0	Yes
06/16/2025	7.99	31.0	Yes
06/17/2025	8.06	30.8	Yes
06/18/2025	8.01	30.5	Yes
06/19/2025	8.05	30.0	Yes
06/20/2025	7.98	30.0	Yes
06/21/2025	7.95	29.0	Yes
06/22/2025	7.94	31.5	Yes
06/23/2025	7.97	30.5	Yes
06/24/2025	7.97	30.5	Yes
06/25/2025	8.04	31.0	Yes
06/26/2025	7.95	30.0	Yes
06/27/2025	8.00	30.0	Yes
06/28/2025	7.97	29.0	Yes
06/29/2025	8.01	31.5	Yes
06/30/2025	8.00	31.5	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance? ☒ Y ☐ N

Supervisor's Signature _____ Print Name Dave Trotter

Certification #: 058778 Phone (503) 635-0394 03-Jul-25