

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: July 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
07/01/2025	8.12	30.5	Yes
07/02/2025	8.00	31.0	Yes
07/03/2025	7.87	31.0	Yes
07/04/2025	7.98	31.0	Yes
07/05/2025	7.97	31.5	Yes
07/06/2025	7.99	32.0	Yes
07/07/2025	7.98	31.5	Yes
07/08/2025	7.93	32.0	Yes
07/09/2025	7.99	32.0	Yes
07/10/2025	8.01	32.0	Yes
07/11/2025	7.99	31.5	Yes
07/12/2025	7.99	31.5	Yes
07/13/2025	8.05	32.5	Yes
07/14/2025	8.08	33.0	Yes
07/15/2025	8.01	32.5	Yes
07/16/2025	7.96	32.5	Yes
07/17/2025	8.01	32.0	Yes
07/18/2025	7.96	32.5	Yes
07/19/2025	7.98	32.0	Yes
07/20/2025	7.95	33.5	Yes
07/21/2025	7.99	33.3	Yes
07/22/2025	7.96	33.5	Yes
07/23/2025	7.95	32.0	Yes
07/24/2025	7.99	32.0	Yes
07/25/2025	8.05	32.0	Yes
07/26/2025	7.97	32.0	Yes
07/27/2025	7.95	33.0	Yes
07/28/2025	7.94	31.8	Yes
07/29/2025	8.00	32.5	Yes
07/30/2025	7.95	31.5	Yes
07/31/2025	7.89	32.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y N

Supervisor's Signature

Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Aug-25