

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: August 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
08/01/2025	7.79	32.0	Yes
08/02/2025	7.86	32.0	Yes
08/03/2025	7.84	33.0	Yes
08/04/2025	7.85	33.0	Yes
08/05/2025	7.78	31.5	Yes
08/06/2025	7.76	33.5	Yes
08/07/2025	7.84	32.5	Yes
08/08/2025	7.86	31.5	Yes
08/09/2025	7.84	33.0	Yes
08/10/2025	7.94	32.5	Yes
08/11/2025	7.91	33.0	Yes
08/12/2025	8.02	33.0	Yes
08/13/2025	7.90	33.0	Yes
08/14/2025	7.99	33.0	Yes
08/15/2025	7.94	32.0	Yes
08/16/2025	7.87	32.0	Yes
08/17/2025	7.90	33.5	Yes
08/18/2025	7.88	33.5	Yes
08/19/2025	7.91	33.5	Yes
08/20/2025	7.91	33.0	Yes
08/21/2025	7.85	32.5	Yes
08/22/2025	7.86	33.0	Yes
08/23/2025	7.88	32.5	Yes
08/24/2025	7.93	34.5	Yes
08/25/2025	7.89	34.0	Yes
08/26/2025	7.90	33.5	Yes
08/27/2025	7.87	32.5	Yes
08/28/2025	7.89	32.0	Yes
08/29/2025	7.90	34.0	Yes
08/30/2025	7.89	33.0	Yes
08/31/2025	7.84	34.0	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature

Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Sep-25