

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: September 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
09/01/2025	7.89	33.5	Yes
09/02/2025	7.89	33.0	Yes
09/03/2025	7.88	33.0	Yes
09/04/2025	7.87	34.0	Yes
09/05/2025	7.83	34.0	Yes
09/06/2025	7.86	34.0	Yes
09/07/2025	7.93	34.0	Yes
09/08/2025	7.89	33.0	Yes
09/09/2025	7.87	32.5	Yes
09/10/2025	7.85	33.0	Yes
09/11/2025	7.87	32.5	Yes
09/12/2025	7.81	32.0	Yes
09/13/2025	7.90	32.0	Yes
09/14/2025	7.92	32.5	Yes
09/15/2025	7.98	33.5	Yes
09/16/2025	7.87	32.0	Yes
09/17/2025	7.91	32.5	Yes
09/18/2025	7.88	32.0	Yes
09/19/2025	7.91	32.5	Yes
09/20/2025	7.91	32.5	Yes
09/21/2025	7.89	32.0	Yes
09/22/2025	7.86	31.0	Yes
09/23/2025	7.90	31.5	Yes
09/24/2025	7.87	33.0	Yes
09/25/2025	7.88	32.0	Yes
09/26/2025	7.87	32.0	Yes
09/27/2025	7.86	32.0	Yes
09/28/2025	7.84	33.0	Yes
09/29/2025	7.81	32.5	Yes
09/30/2025	7.89	32.5	Yes

Number of excursions this month = 0
Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature _____ Print Name Dave Trotter

Certification #: 058778 Phone (503) 635-0394

03-Oct-25