

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: October 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
10/01/2025	8.09	32.5	Yes
10/02/2025	8.07	33.5	Yes
10/03/2025	8.03	33.0	Yes
10/04/2025	8.05	33.0	Yes
10/05/2025	8.00	32.0	Yes
10/06/2025	8.07	32.5	Yes
10/07/2025	8.05	32.5	Yes
10/08/2025	8.03	32.5	Yes
10/09/2025	8.00	32.5	Yes
10/10/2025	7.95	32.5	Yes
10/11/2025	7.96	32.5	Yes
10/12/2025	8.01	32.5	Yes
10/13/2025	7.96	32.5	Yes
10/14/2025	7.87	32.5	Yes
10/15/2025	7.89	32.0	Yes
10/16/2025	7.89	32.0	Yes
10/17/2025	7.92	32.0	Yes
10/18/2025	7.96	32.0	Yes
10/19/2025	7.98	32.0	Yes
10/20/2025	8.02	31.5	Yes
10/21/2025	7.97	32.5	Yes
10/22/2025	7.89	31.5	Yes
10/23/2025	7.92	31.5	Yes
10/24/2025	7.99	31.5	Yes
10/25/2025	7.95	32.0	Yes
10/26/2025	7.98	31.0	Yes
10/27/2025	8.00	32.0	Yes
10/28/2025	7.90	31.5	Yes
10/29/2025	7.80	30.0	Yes
10/30/2025	7.96	28.5	Yes
10/31/2025	7.88	28.0	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature

Dave Trotter

Digitally signed by Dave
Trotter
Date: 2025.11.06 09:41:16
08:00'

Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Nov-25